



LEAD AND COPPER SAMPLING RESULTS

June-September 2021 90TH PERCENTILE

SC4510001 GREELEYVILLE TOWN OF (4510001)

Below are the individual results for each sample site from the June-September 2021 monitoring period.

The 90th percentile for lead was 0.0015 mg/L and for copper 0.03 mg/L for the 10 samples analyzed.

The public water system must deliver Customer Notice of Lead and Copper Results in Drinking Water within 30 days of receiving these test results from DHEC. This notice must contain the content as outlined in State Primary Drinking Water Regulation R.61-58.11.G(4)(c):

- the results of lead tap water monitoring for the tap that was tested
- an explanation of the health effects of lead
- list steps consumers can take to reduce exposure to lead in drinking water
- contact information for the water utility
- the maximum contaminant level goal and the action level for lead and the definitions for these two terms from R.61-58.12.C(3).

As per R.61-58.11.G(4)(d) the consumer notice must be provided to persons served at the tap that was tested, either by mail or by another method approved by the Department. For example, upon approval by the Department, a non-transient non-community water system could post the results on a bulletin board in the facility to allow users to review the information. The system must provide the notice to customers at sample taps tested, including consumers who do not receive water bills. After notification is completed the Consumer Information Notice Form must be filled out and returned to DHEC.

The next sampling schedule is 10 samples to be collected during the 06/01/2024 - 09/30/2024 monitoring period.

T-CODE	DESCRIPTION	COLLECTION DATE	COPPER (mg/L)	LEAD (mg/L)
T1A0005	T1A0005	8/17/2021	0.013	0.00026
T1A0019	T1A0019	8/17/2021	0.012	0.0011
T3A0001	T3A0001	8/17/2021	0.0073	0.00016
T3A0002	T3A0002	8/16/2021	0.03	0.0022
T3A0007	T3A0007	8/19/2021	0.0054	0.00031
T3A0009	T3A0009	8/18/2021	0.012	0.0015
T3A0010	T3A0010	8/18/2021	0.021	0.0002
T3A0020	T3A0020	8/19/2021	0.0036	0.000069
T3A0026	T3A0026	8/17/2021	0.064	0.00086
T3A0027	T3A0027	8/17/2021	0.022	0.00021
90th Percentile			0.03 mg/L	0.0015 mg/L

If you have any questions or concerns contact one of the DHEC staff members below.

Ana Barber
 Env. Health Manager
 Office:(803)898-4154
 barberae@dhec.sc.gov

DHEC
 Bureau of Water
 Fax:(803)898-3795
 2600 Bull Street
 Columbia, SC29201



LEAD AND COPPER SAMPLING RESULTS June-September 2021 90TH PERCENTILE

SC4510001 GREELEYVILLE TOWN OF (4510001)